

Town of Walnut Cove

Fire Marshal's Office

Statement of Compliance

Section 901.2.1 of the North Carolina State Fire Prevention Code states the following:

“Before requesting final approval of the installation, where required by the Code Official, the installing contractor shall furnish a written statement to the Code Official that the subject fire protection system has been installed in accordance with approved plans and has been tested in accordance with the manufacturer’s specifications and the appropriate installation standard. Any deviation from the design standards shall be noted and copies of the approvals for such deviations shall be attached to the written statement.”

The above reference Statement of Compliance shall be furnished to the Town of Walnut Cove Fire Marshal's Office upon request for a final inspection of any fire protection system installation. This Statement of Compliance shall be on the installing companies' letterhead with the project name and address clearly indicated along with the type of fire protection system installed. The installer shall print their name and sign their name to this Statement of compliance.

Additional certifications or information may be required at the final inspection, such as aboveground and belowground test certificates for sprinkler and standpipe systems and record of completion forms for fire alarm systems.