

Town of Walnut Cove

Hood Suppression System Requirements

Business Name: _____ Site Address: _____
Property Owner: _____ Phone: _____
System Contractor: _____ Address: _____
Phone: _____ Fax: _____ Email: _____
Building Contractor: _____ Address: _____
Phone: _____

Type of Work: New Construction Alteration Addition

Type of System: FM 200 Wet Chemical Dry Chemical

Number of Nozzles: _____

Nozzle types: _____

Number of Tanks: _____

Size of Tanks: _____

The following information must be submitted with, or on the plans: - Completed Permit application - Size, length and arrangement of piping - Description and location of nozzles from protected appliances. - Location on function of detection devices, operating devices, auxiliary and electrical circuitry if used. - Flow rate per nozzle(s). Manufacturer's requirements.

The fee for suppression systems review is \$100.00.

Plans are reviewed on a first-come, first-serve basis. Re-review will be treated as a first submit.

Signature: _____ Date: _____

Office Use Only

Two sets of plans submitted Y or N Date Received _____ Plans Approved Y or N

Approved by: _____ Permit # _____ Date: _____

Fee: _____ Cash: _____ Check #: _____

Codes used in the review: North Carolina State Fire Prevention North Carolina State Building North Carolina State Accessibility Applicable National Fire Protection Association Standards ♦ Additional information may be required prior to approval of the submitted plans. The above requested information is not all-inclusive.